






Active Fire-Rated Coat Hook Instructional Guide








Installation Steps:

- 1. Clean surface area of debris before installing
- 2. Mount back plate on door using 3M Double Sided Tape provided

| Technical Specs: | |
|------------------|----------------------|
| Hook Item | Double Point Hook |
| Fastening | 3M Double Sided Tape |
| Points per Hook | 2 |
| Number of Hooks | 1 |
| Hook Material | Stainless Steel |
| Weight Capacity | 4lbs. |
| Hook Height | 5 1/4 in. |
| Hook Base Width | 2 in. |
| Projection | 4 1/4" in. |
| Includes | Mounting Hardware |
| | |

^{*}This product will meet the requirement of UL 10C (2016), UBC 7-2 (1997), NFPA 252 (2017) and NFPA 80 2010, 2013, 2016, 2019 2016, 2019





Active Fire Door Excessive Gap Products SPEC ID: 58841

Active Fire Door Products Inc.

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service must be approved in the certification program.



Unless otherwise noted, assemblies in this section have been evaluated to the following standards:

UL 10C, Positive Pressure Fire Test of Door Assemblies NFPA 252, Fire Test of Door Assemblies CAN/ULC S104, Standard Method for Fire Test of Door Assemblies

| Attribute | Value |
|---------------------------------|------------------------------------|
| Criteria | CAN / ULC S104 (2015) |
| Criteria | UL 10(c) (2016) |
| Criteria | NFPA 252 (2017) |
| CSI Code | 08 70 00 Hardware |
| Fire Resistance | 45 Min Positive Pressure |
| Fire Resistance | 90 Min Positive Pressure |
| Fire Resistance | 60 Min Positive Pressure |
| Fire Resistance | 20 Min Positive Pressure |
| Intertek Services Certification | |
| Listed or Inspected | LISTED |
| Listing Section | DOOR & FRAME HARDWARE |
| Report Number | G104482767, G104482767, G104599653 |
| Spec ID | 58841 |

Verification Testing No